

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1113

Dated: 16/05/2026

It is certified that an inspection team headed by Mammit Raj Mishra (Asst. Engineer)
 (Name of Officers with designation) from Public Health Engineering Dept. Sitamarhi
 (Name of Department/ Office) inspected the DPS (Lagma)
 (Name & Address of the school) on 15/5/2026 (date of inspection) and found that
 the Delhi Public School, Lagma (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of 6 Months

Signature with Seal: 16/5/2026

Name

Arjun Prakash

Designation

Executive EngineerEXECUTIVE ENGINEER
P. H. ENGINEERING DIVISION SITAMARHI

Name & Address of the Office / Department :

To

Delhi Public SchoolLagma, Sitamarhi

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Sitamarhi

District Name : Sitamarhi

Name of School-Delhi Public School Lagma

Month : May 2026

Sl. No.	Testing Date	Block	Panchayat	Village/Ward	Source	Location of Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	NO ₃	SO ₄
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
1	15.05.2026	Dumra	Lagma	Lagma	Submersible	Lagma	7.40	1.5	254	165	158	38	28	28	175	0.3	1.5	8.5
Desirable Limit **							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200
Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision)							NR	5.0		2000	600	200	100	1000	600	1	NR	400

Note: (1) Drinking Water Specification First Revision -IS:10500:2012, Edition 2.2(2003-09,12,20)(Reaffirmed1993), (2) BDL = Below Detection Limit, (3)NR = No Relaxation, (4) ND = Not Done.

- (a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml, (c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Copy forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt. of Bihar, (ii) Director, Water Quality Cell, PHED, Govt. of Bihar, (iii) SLWTL, PHED, Govt. of Bihar.

Signature
15/5/2026
Chemist

P.H Division Sitamarhi

Signature
15/5/2026
Assistant Engineer
P.h Sub Division Sitamarhi